



City of Tacoma

Questions and Answers

RAIL CROSSING IMPROVEMENTS 6TH AVE & S 19TH ST RFB Specification No. PW24-0257F

All interested parties had the opportunity to submit questions in writing by email to Carly Fowler, Senior Buyer by November 25, 2024. The answers to the questions received are provided below and posted to the City's website at www.TacomaPurchasing.org. Navigate to [Current Contracting Opportunities / Public Works and Improvements Solicitations](#), and then click [Questions and Answers](#) for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

Question 1: When looking over the given quantities in this project per Add. 3 I noticed there is no bid item for barrier curb when it is called out directly in the plans (construction note 20). There is also a callout for Cement Concrete 8" (bid item R-26) that has a quantity of 0 per Schedule B (S19th), but our takeoff shows approx. 13SY. I would appreciate clarification on these items.

Answer 1: Barrier curb is used interchangeably with Traffic Curb and shall be paid per LF of Traffic Curb. 8" Cement Conc. Pavement on S 19th shall be paid for as Cement Conc. Driveway. It is an 8" Concrete Section per City of Tacoma Standard Plans.