



City of Tacoma

Questions and Answers

LEACH CREEK STORMWATER HOLDING BASIN MODIFICATIONS REBID RFB Specification No. **ES23-0281F**

All interested parties had the opportunity to submit questions in writing by email to Dawn DeJarlais, Senior Buyer by January 29, 2024. The answers to the questions received are provided below and posted to the City's website at www.TacomaPurchasing.org. Navigate to [Current Contracting Opportunities / Public Works and Improvements Solicitations](#), and then click *Questions and Answers* for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

Question 1: Will you please consider redesigning the precast 60" riser section? There are no precasters who can make the 60" precast section in one 10' piece and they have all declined to quote the project.

Answer 1: The specification allows for the precast concrete manhole base and risers to be fabricated in multiple sections provided it meets the requirements of Specification Sections 03510 1.03 B.1. and Section 03510 2.02 A.