



City of Tacoma

Questions and Answers

FOSS SHORELINE RESTORATION SLOPE CAP REPAIR PROJECT RFB Specification No. **ES25-0022F**

All interested parties had the opportunity to submit questions in writing by email to Stan Rowden, Senior Buyer By May 26, 2025. The answers to the questions received are provided below and posted to the City's website at www.TacomaPurchasing.org. Navigate to [Current Contracting Opportunities / Public Works and Improvements Solicitations](#), and then click [Questions and Answers](#) for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

Question 1:

we request clarification regarding access requirements for Site TA3:

Will the City of Tacoma allow all construction activities at TA3 to be completed from upland access, utilizing a long reach excavator and trucks positioned on the upland bank, rather than requiring barge-based or water-based equipment?

Answer 1: Water-based equipment will be used to complete the repair activities at RA 3.