


NOTES

1. For details showing grade ring, ladder, steps, handholds and top slabs, see Standard Plan No. SU-21.
2. Non-reinforced concrete in channel and shelf shall be Class 3000. All precast concrete shall be Class 4000.
3. Rubber gaskets shall be used in tongue and groove joints of pre-cast sections.
4. A flexible pipe-to-manhole connector shall be employed in all connections of rigid and flexible pipes to new precast concrete manholes. The connector shall be "Kor-N-Seal" with "Wedge Korband" manufactured by NPC, Inc., or approved equal.
5. Base reinforcing steel shall be per manufacturer's recommendation.

INSIDE DIAMETER	MINIMUM WALL THICKNESS	MINIMUM BASE THICKNESS	MAXIMUM HOLE SIZE	MINIMUM DISTANCE BETWEEN HOLES
72"	6"	8"	60"	12"
84"	8"	12"	72"	12"
96"	8"	12"	84"	12"
108"	10"	12"	96"	12"
120"	11"	12"	108"	12"

Initial BW REVIEWED BY Initial EW
 PUBLIC WORKS ENVIRONMENTAL SERVICES
 Initial MR Initial TF
 TACOMA POWER TACOMA WATER



APPROVED FOR PUBLICATION
 Signed by: Ramiro Chavez, P.E. PgM 09/15/2025
 DATE

CITY OF TACOMA
 MANHOLE - TYPE 2
 72" AND GREATER
 STANDARD PLAN NO. SU-18