



City of Tacoma

## Tacoma Power/Transmission & Distribution

**ADDENDUM NO. 1**

**DATE:** 4/16/2026

**REVISIONS TO:**

**Request for Bids Specification No. PT26-0045F  
Substation Retrofit**

**NOTICE TO ALL BIDDERS:**

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

**REVISIONS TO THE SUBMITTAL DEADLINE:**

The submittal deadline remains the same.

**REVISIONS TO THE TECHNICAL PROVISIONS:**

Replace the detail road description sheet in the scope of work in Appendix A with the version marked Addendum 1. This sheet matches the proposal pages for the information regarding the hole information to be quoted as part of the scope.

**NOTE:** Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the signature page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked Request for Bids Specification No. PT26-0045F Addendum No. 1. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

cc: Erica Pierce, Tacoma Power T&D

Items #	# of Holes	Depth (ft.)	Rod diameter (in.)	In GEM (4 in. diameter hole)
1	3	64	0.75	3 augered holes (4" dia) with 8 rods(with GEM) in each hole at 3 different locations.
2	5	40	0.75	5 augered holes (4" dia) with 5 rods(with GEM) in each hole at 5 different locations.
3	15	24	0.75	3 coupled rods will be driven at 24 ft in depth at 15 locations into the native soil.
4	9	16	0.75	2 coupled rods will be driven at 16 ft in depth at 9 locations into the native soil.

updated as of 4/9/26

### Notes

For construction prints, as the sample drawing below, the prints will have details of all the locations where rods or rods+GEM+holes will be located.

All pertinent information will be included in these prints, which will be provided to the awarded vendor prior to work beginning.

