



City of Tacoma

Questions and Answers

Links to Opportunity Streetscape – Bid Package 4 RFB Specification No. PW25-0136F

All interested parties had the opportunity to submit questions in writing by email to Carly Fowler, Senior Buyer by March 20, 2026. The answers to the questions received are provided below and posted to the City's website at www.TacomaPurchasing.org. Navigate to [Current Contracting Opportunities / Public Works and Improvements Solicitations](#), and then click [Questions and Answers](#) for this Specification. This information IS NOT considered an addendum. Respondents should consider this information when submitting their proposals.

Question 1: I don't see a bid item for Driveways on this project. No driveway payment in the specs. The sidewalk specs do not mention driveways and the quantity of sidewalk is not enough to include them. Will you be adding a bid item for them I have approximately 187 sy.

Answer 1: Bid Item R-55 has been changed to reference the 2025 WSDOT Standard Specification **8-06.5 Payment**,

Cement Conc. Driveway Entrance, Type _____, per square yard

See Bid Proposal marked Addendum No.2.

Question 2: Would the concrete for the driveways be high early to allow for quick access? For the Concrete paving, specs are calling out a 28 day compressive strength. Wouldn't a 24hr be required so traffic can be put back on quickly?

Answer 2: See addendum No. 2 special provision **8-06.3 Construction Requirements** supplemental information regarding driveway entrance closure time. Concrete submittal should reflect curing times to meet this special provision.