



Event Addendum(s)

## Table of Contents

Addendum 01 - [1/6/2026]..... 2



---

## Addendum 01 – 01/06/2026

### **REVISIONS TO:**

**RFB Specification No. ES25-0276N  
WASTEWATER TREATMENT PLANT ELECTRIC  
SECURITY FENCE SYSTEM AND SERVICE**

### **NOTICE TO ALL RESPONDENTS:**

This addendum is issued to clarify, revise, add to or delete from, the original specification documents for the above project. This addendum, as integrated with the original specification documents, shall form the specification documents. The noted revisions shall take precedence over previously issued specification documents and shall become part of this contract.

### **REVISIONS TO THE SUBMITTAL DEADLINE:**

The submittal deadline remains the same.

### **REVISIONS TO THE TECHNICAL REQUIREMENTS:**

Section 3. Performance and System Requirements is replaced with the below:  
Fence Structure:

- High-tensile galvanized steel wire. The City will also allow the use of aluminum wire in limited locations where it is necessary to integrate with existing steel security panel fencing. All other areas shall utilize high-tensile steel wire as specified in the bid documents. Any use of aluminum wire must meet the performance, durability, and operational requirements of the fence system outlined in the specifications.
- Minimum twenty (20) horizontal strands in a single-strand configuration.
- Approximate fence height: ten (10) feet, subject to permitting limits.
- Tamper-resistant insulators, posts, and hardware.
- Integrated earthing and lightning protection at steel poles and solar assemblies.

### **REVISIONS TO THE TECHNICAL REQUIREMENTS:**

Section 7. Installation and Site Conditions is replaced with the below:

- City will provide site access and clear vegetation.
- Contractor will perform all installation activities including trenching (if required), grounding, wiring, post installation, solar mounting, energizer setup, and system commissioning.
- Contractor will locate/protect underground utilities, obtain clearances, and meet all safety requirements.
- Installation shall not begin until permits are issued.



## Event Addendum(s)

- Installation and removal work will be during business hours Monday – Friday (7:00am – 3:00pm)
- The completion period will be measured from the date the required permits are issued by the City and shall not exceed 90 days. The awarded vendor will be responsible for submitting complete and timely permit applications and for coordinating with the City to avoid delays associated with permitting.

NOTE: Acknowledge receipt of this addendum by initialing the corresponding space as indicated on the signature/proposal page. Vendors who have already submitted their bid/proposal may contact the Purchasing Division at 253-502-8468 and request return of their bid/proposal for acknowledgment and re-submittal. Or, a letter acknowledging receipt of this addendum may be submitted in an envelope marked RFB Specification No.ES25-0276N Addendum No.01. The City reserves the right to reject any and all bids, including, in certain circumstances, for failure to appropriately acknowledge this addendum.

---