

CITY OF TACOMA
REQUEST FOR QUOTATION
GENERAL TERMS AND CONDITIONS

This Request for Quotation is governed by City of Tacoma Standard Terms and Conditions linked below.

<http://cms.cityoftacoma.org/purchasing/StandardTermsandConditions.pdf>



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

**REQUEST FOR QUOTATION
6000053610**

Return Bids By 11:00 AM, 04/24/2026 to: sendbid@tacoma.gov
Merry Mitchell Water Purchasing ABN 4th Floor NE 3628 South 35th Street Tacoma WA 98409
Material will ship to:
Water Warehouse 3506 S 35th St Tacoma WA 98409

RFQ Information	
Collective Bid #	TW26-0098N
Bid Issue Date	04/14/2026
Vendor Number	109226 WEB VENDOR FOR RFQ
Vendor Information (vendor to complete)	
Firm Name:	
Address:	
City/State/Zip	/ /
Phone/Fax	/
E-Mail	
Contact Name	
Payment Terms	%, days (e.g. 2% 10,N30)
Tacoma Bus. Lic. #	
Taxpayer ID #	
SIGNATURE OF PERSON AUTHORIZED TO SIGN THIS BID	
x _____	DATE: ___ / ___ / _____
NAME : _____	
TITLE : _____	

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
	<p>The City of Tacoma is soliciting bids for purchase of Hardware Non-Electrical (Stock) & Operating Supplies (Stock)</p> <p>Submittals may be e-mailed to sendbid@tacoma.gov for this solicitation.</p> <p>Please include the Collective Bid Number, TW26-0098N, in the subject line of your e-mail.</p> <p>Bids are subject to the submittal deadline noted in the bid solicitation document. The time of e-mail receipt will be considered as the time of submittal. The city accepts no responsibility for transmission errors.</p> <p>We are unable to verify receipt of submittals due to the large volume of submittals received.</p> <p>Extend net price and provide net total value. All bid pricing shall be FOB Destination, freight prepaid and included in the unit price.</p> <p>Materials must be new and unused. No substitutes are allowed. Substitute items will be returned at vendor's expense.</p>					



CITY OF TACOMA

THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION 6000053610

Item #	Material# Description	Delivery Date	QTY	UM	Net Price	Total
	<p>Delivery date will default to two weeks ARO if vendor fails to provide.</p> <p>Please Circle or underline the part number and manufacturer quoted or bid may be considered non-responsive.</p> <p>If applicable, you must select from the approved manufacturer(s) listed. Substitutions will not be approved at the time of the bid awarding. If you have a material that you would like to have added, it must be submitted for review and approved by the City of Tacoma's Material Committee before the bid issue date listed on this request for quotation. For more information regarding this process, please contact: Merry Mitchell, mmitchell@tacoma.gov</p> <p>Responses MUST BE SUBMITTED on the provided City of Tacoma bid solicitation form. Vendor signature is MANDATORY.</p> <p>Bid results will be posted at: http://www.cityoftacoma.org/government/city_departments/finance/procurement_and_payables_division/purchasing/bid_results/ Note: You must register at this website as a bid holder for each solicitation of interest in order to receive notification regarding amendments or other updates to the original bid solicitation documents.</p> <p>City Contact: Merry Mitchell, mmitchell@tacoma.gov</p>					
10	<p>31841 VALVE,2IN IPT,GATE,BRONZE VALVE, 2IN, GATE, BRONZE, 2IN IPT THREADED, SCREWED BONNET NON-RISING STEM, 125 LB.</p> <p>BRASS COMPONENTS THAT CONTACT WATER MUST MEET NSF/ANSI 372, AND IDENTIFIED AS SUCH ON THE PRODUCT.</p>		4	EA		



CITY OF TACOMA

THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be
 plainly marked with this

**REQUEST FOR
 QUOTATION
 6000053610**

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
20	31961	<p>CAP,3/8IN,PIPE,BRASS CAP, 3/8 INCH (.3750), PIPE, BRASS.</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT</p>		5	EA		
30	32010	<p>COUPLING,3/4INX1/4IN,PIPE,REDUCING,BRASS COUPLING, PIPE, REDUCING, BRASS, 3/4 INCH X 1/4 INCH</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT"</p>		5	EA		
40	32012	<p>COUPLING,3/4INX1/2IN,PIPE,REDUCING,BRASS COUPLING, PIPE, REDUCING, BRASS, 3/4IN X 1/2IN.</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT"</p>		10	EA		



CITY OF TACOMA

THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION 6000053610

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
50	32079	<p>INSERT,3/4,RIBBED,BOTH ENDS INSERT, 3/4 INCH, RIBBED INSERT, BOTH ENDS, FOR PE PIPE</p> <p>BRASS COMPONENTS THAT CONTACT POTABLE WATER MUST MEET ANSI/AWWA C800 AND NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT. BRASS COMPONENTS THAT DO NOT CONTACT POTABLE WATER MUST MEET AWWA/ANSI C800 AND MAY BE MANUFACTURED WITH 85-5-5-5 BRASS, UNS NO C83600.</p> <p>Material # Manf Part# Manufacturer Name 32079 PTP-1NL FORD METER BOX CO</p>		20	EA		
60	32122	<p>NIPPLE,1IN X 4IN,RED BRASS NIPPLE,RED BRASS, 1IN X 4IN</p> <p>MUST MEET ASTM B43 FOR SEAMLESS RED BRASS PIPE AND NSF 372 FOR LEAD CONTENT.</p>		10	EA		
70	32336	<p>MUELLER,6IN,SUP CENT 200,UPR STEM,ST MUELLER, 6IN, SUPER CENTURION 200, HYDRANT PART ITEM A-11, UPPER OPERATING STEM, STEEL.</p>		4	EA		
80	32385	<p>CLOW MED,M-28,THRUST NUT,O-RING CLOW, MEDALLION, HYDRANT PART, ITEM M-28, THRUST NUT O-RING, NBR#</p>		3	EA		
90	33373	<p>COUPLING,4IN,GALV COUPLING, GALVANIZED, 4 INCH, MALLEABLE IRON, CLASS 150, GALVANIZED PER ASTM A153</p>		1	EA		



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION
6000053610

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
100	33900	<p>CLAMP,1/2IN-1IN,HOSE,SS CLAMP,HOSE,ALL STAINLESS STEEL,ADJUSTABLE.RANGE-FROM 1/2 IN. TO 1 IN. INCLUDING S.S.SCREW.#</p> <p>Material # Manf Part# Manufacturer Name 10000172 10HS WITTEK 10000173 620-010 TRIDON 10000174 HAS10 OR HHS10 DIXON 10000175 6810 IDEAL CLAMP PRODUCTS 10000176 V010 BAND-IT</p>		50	EA		
110	32143	<p>PLUG,3/8IN,BRASS,IPT PLUG, BRASS, .3750 (3/8IN), IPT</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET ANSI/AWWA C800 and NSF/ANSI 372 AND IDENTIFIED AS COMPLIANT.</p>		10	EA		
120	32348	<p>MUELLER,6IN,SUP CENT 200,UPR VLV PLATE MUELLER, 6 INCH, SUPER CENTURION 200, HYDRANT PART ITEM A-36, UPPER VALVE PLATE, BRONZE.</p> <p>Material # Manf Part# Manufacturer Name 32348 A-36 MUELLER</p>		1	EA		
130	33887	<p>SHOVEL,LONG HANDLE,SPADE</p> <p>SHOVEL, SPADE, LONG HANDLE, MIN. 47"-49" HANDLE,BLADE 7"X12", OPEN BACK, TURNED STEP</p> <p>APPROVED: UNION 46109 (REPLACES 461-059) TRUE TEMPER 42600 RAZORBACK TRUE TEMPER CSHL OR SDL</p> <p>NOT ACCEPTABLE: TRUE TEMPER DGS</p>		2	EA		



CITY OF TACOMA

THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be
 plainly marked with this

REQUEST FOR QUOTATION 6000053610

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
	Material #	Manf Part#	Manufacturer Name				
	10000135	SDL	TRUE TEMPER				
	10000136	CSHL	TRUE TEMPER				
	10000137	46109	UNION TOOLS				
	10010800	42600 RAZORBACK	TRUE TEMPER				
140	30519	BLOCK,4IN X 8IN X 16IN,CONCRETE,SOLID BLOCK, CONCRETE, SOLID, 4IN X 8IN X 16IN. MADE WITH SAND, GRAVEL, AND PORTLAND CEMENT, FOR FIRE HYDRANT BASES.		120	EA		
150	31349	PACKING,1/8IN X 48IN,RBR SH,COMMERCIAL PACKING, RUBBER SHEET, 1/8 INCH THICK X 48 INCH WIDE, WITH CLOTH BACKING, COMMERCIAL GRADE, RED, SUPPLIED IN 100 POUND ROLLS.		100	LB		
160	32333	MUELLER,6IN,SUP CENT 200,ANTI FRICTION W MUELLER, 6INCH, SUPER CENTURION 200, HYDRANT PART ITEM A-6, ANTI FRICTION WASHER, PLASTIC#		3	EA		



THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION
6000053610

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
170	36365	<p>VALVE,4IN,GATE,MJ X MJ **** GATE,VALVE, MJ X MJ, 4IN, CAST IRON, WITH 2" OPERATING NUT WHICH OPERATES LEFT TO OPEN (COUNTER CLOCK WISE), NON RISING STEM, UL LISTED AND FM APPROVED, VALVES SHALL CONFORM TO THE LATEST C515 AND AWWA C550. FLANGED ENDS SHALL CONFORM TO REVISION OF AWWA C110/A21.10, (ANSI B16.1, CLASS 125)</p> <p>Material provided under this specification must be manufactured within two years of the date of the purchase order unless prior approval is obtained from Tacoma Water.</p> <p>APPROVED: AMERICAN FLOW SERIES 2500, CLOW MODEL RS, KENNEDY MODEL RWGV-96, M&H STYLE 4067, MUELLER STYLE 2360, US PIPE METROSEAL 250, AVK MODEL NO. 25-100-00 EAST JORDAN IRON WORKS "FLOW MASTER"</p> <p>***** NOT ACCEPTABLE: AMERICAN DARLING *****</p>		15	EA		
180	32156	<p>TEE,3/4IN,BRASS TEE, 3/4 INCH, BRASS, FEMALE IRON PIPE INLET, OUTLET AND BRANCH.</p> <p>MATERIAL PROVIDED UNDER THIS SPECIFICATION MUST MEET NSF/ANSI 372, AND IDENTIFIED WITH "NL" ON THE PRODUCT.</p>		18	EA		



CITY OF TACOMA

THIS IS NOT AN ORDER
All prices quoted shall be F.O.B.
Destination, Freight Prepaid and Allowed

All responses & inquiries must be plainly marked with this

REQUEST FOR QUOTATION
6000053610

Item #	Material#	Description	Delivery Date	QTY	UM	Net Price	Total
190	32725	<p>HYDRANT,6IN,DRY BARREL,4.5FT BURY,DI,MJ HYDRANT, 6IN., DRY BARREL, 4-1/2 FT. BURY, DUCTILE IRON, MJ 5-1/4 MAIN VALVE OPENING, ONE 4-INCH PUMPER NOZZLE, TWO 2.5-7.5 NH OUTLET NOZZLES, OPENING TO THE LEFT (COUNTER CLOCKWISE), PAINTED ALUMINUM COLOR WITH POLY-SILICON ENAMEL SUCH AS KEELER & LONG "P" SERIES OR EQUAL. THE HYDRANT MUST MEET ANSI/AWWA STANDARD C502-85 OR LATEST REVISION. FIRE HYDRANTS SHALL HAVE 4-INCH TACOMA STANDARD THREADS ON THE PUMPER NOZZLE UNLESS SPECIFIED OTHERWISE. THE PUMPER NOZZLE SHALL BE THREADED INTO HYDRANT CASTING. THE DRIP BALVES ON ALL FIRE HYDRANTS MUST CLOSE COMPLETELY IN FOUR OR LESS REVOLUTIONS OF THE OPERATING NUT.</p> <p>APPROVED: CLOW "MEDALLION" KENNEDY "GUARDIAN K81D" M&H 129, "RELIANT" MUELLER "SUPER CENTURION 250" WATEROUS "JPACER/WB67-250, TACOMA" EAST JORDAN "WATER MASTER-5CD250"</p>		10	EA		

Net Value	\$
Plus Tax at	
_____ %	\$
Total Amount	\$